

**From:** Jeff Luthman  
**To:** [Brennan, Dan](#)  
**Subject:** Nayadic tie down and site tube  
**Date:** Wednesday, August 1, 2018 11:30:05 AM  
**Attachments:** [58913239-521A-446E-87D9-DE71360CA183.png](#)

---

Dan,

I got your message and to answer your question yes it is acceptable to remove the site tube if the Unit is going to be anchored down.

Kind regards,

**Jeff Luthman**  
General Manager

**CONSOLIDATED**  
TREATMENT SYSTEMS  
[www.consolidatedtreatment.com](http://www.consolidatedtreatment.com)  
**937-550-2215**